

CABLE ALEACION ALUMINIO AAAC
RESA


Área nominal	La construcción de conductor	Zona calculada	Diámetro total	El peso	Resistencia a 20 cc
Mm2	N/mm	Mm2	Mm	Kg/km.	Ω/km.
16	7/1.70	15.9	5.1.	43.5	2.091
25	7/2.10	24.2	6.3	66.4	1.370
35	7/2.50	34.4	7.5	94.1	0.9669
50	7/3.00	49.5	9.0	135	0.6714
50	19/1.80	48.3	9.0	133	0.6905
70	19/2.10	65.8	10.5	181	0.5073
95	19/2.50	93.3	12.5	257	0.358
120	19/2.80	117	14	322	0.2854
150	37/2.25	147	15.7	406	0.2274
185	37/2.50	182	17.5	501	0.1842
240	61/2.25	243	20.2	671	0.1383
300	61/2.50	299	22.5	828	0.1120
400	61/2.89	400	26.0	1.106	0.0838
500	61/3.23	500	29.1	1382	0.06709
625	91/2.96	626	32.6	1.735	0.05367
800	91/3.35	802	EI 36,9	2.222	0.0419
1000	91/3.74	1.000	41.1	2.770	0.03362